



Product Service

# Attestation of Conformity

No. N8A 118706 0011 Rev. 00

**Holder of Attestation:** SUZHOU DOART ROCKCORE ENERGY AND TECHNOLOGY CO.,LTD.  
19F-D, Doart Mansion, No. 258 of ChunXu Road  
Kunshan Development Zone  
215300 Suzhou  
PEOPLE'S REPUBLIC OF CHINA

**Product:** Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
Mono -Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704062317502-00

**Date,** 2024-01-08

( Zhulin Zhang )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®



Product Service

# Attestation of Conformity

No. N8A 118706 0011 Rev. 00

**Model(s):** DA-M10/108H-xxxW, xxx=390 to 415 in steps of 5,  
DA-M10/120H-xxxW, xxx=430 to 465 in steps of 5,  
DA-M10/144H-xxxW, xxx=520 to 555 in steps of 5,  
DA-M10/108HN-xxxW, xxx=420 to 440 in steps of 5,  
DA-M10/120HN-xxxW, xxx=470 to 485 in steps of 5,  
DA-M10/144HN-xxxW, xxx=560 to 585 in steps of 5,  
xxx is standing for rated output power at STC

## Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790

## Tested according to:

EN IEC 61730-1:2018  
EN IEC 61730-1:2018/AC:2018-06  
EN IEC 61730-2:2018  
EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®